

**RESOLUTION NO. 1808**

**A RESOLUTION OF THE CITY OF NEVADA MISSOURI, AUTHORIZING PAYMENT TO MCINROY CONTRACTORS LLC, NEVADA, MISSOURI, FOR THE EMERGENCY REPAIR OF THE PRODUCT LINE**

**WHEREAS**, the City of Nevada authorizes payment to McInroy Contractors, LLC; and

**WHEREAS**, an invoice was received in the amount of \$27,850.00; and

**WHEREAS**, the City Manager or his designee is hereby directed to execute any and all documents related to said invoice.

**NOW, THEREFORE, BE IT RESOLVED** that the City Council of the City of Nevada, Missouri, authorizes payment to McInroy Contractors, LLC Nevada Missouri for the emergency repair of the product line.

**PASSED, APPROVED AND ADOPTED**, by the City Council of the City of Nevada, Missouri on this 3rd day of September, 2024.



(seal)

**ATTEST:**

**CYNTHIA DYE, CITY CLERK**

**GEORGE C KNOX, MAYOR**

**AGENDA ITEM**  
September 3, 2024

Subject: Product Line Repair

Department: Water Treatment Plant

**Department Head Notes:**

- The WTP developed multiple leaks in the produce water line. The water would flow into the R.O. room and meeting room downstairs. Within a matter of days the flow increased rapidly. All of the concrete lined fittings of the product line were just about completely destroyed.

**Manager Notes:**

- Chapter 26 section 26-18 Procurement in exceptional emergency or extraordinary circumstances. Gives the City Manager purchasing authority over \$5,000 if the purchase is a public necessity, health or safety.

8-16

# Invoice

McInroy Contractors LLC  
1291 E Highland Ave  
Nevada, MO 64772 US  
+14176671736  
nathan@mcinroycontractorsllc.com

BILL TO  
City of Nevada MO  
110 South Ash  
Nevada, MO 64772

SHIP TO  
City of Nevada MO  
Joe Tipper  
110 South Ash  
Nevada, MO 64772

INVOICE #	DATE	TOTAL DUE	DUE DATE	TERMS	ENCLOSED
2024-LLC23	07/26/2024	\$27,850.00	08/25/2024	Net 30	

P.O. NUMBER  
Water Treatment Plant

DATE	SERVICE	DESCRIPTION	QTY	RATE	AMOUNT
	02 Site Work	Emergency replacement of product line fittings: Upon excavation of existing product line, it was discovered that two fittings had deteriorated and were leaking. Material was located and next day aired from three separate locations in the nation to this site. Two ductile 45 degree fittings were cut out and replaced with 10" Schedule 80 PVC 45 degree fittings with four stainless repair clamps and 10" CL200 PVC pipe. Site was restored and reseeded. Labor & Materials	1	25,000.00	25,000.00
	02 Site Work	Removed existing 5 foot diameter pit. Removed existing deteriorated fittings from lines and replaced with 6" mechanical joint caps on both sides. Backfill with gravel. Labor & Materials	1	2,850.00	2,850.00

Thank you for your business. Please contact Nathan should you have any questions. (Cell 417-667-1736)

BALANCE DUE

**\$27,850.00**

Posted  
JUL 29 2024

Acct. # 500-5-4425-232  
Dept. Head. [Signature]  
City Mgr/Pur. Agent \_\_\_\_\_